

DC Microgrids and Distribution Systems for Residences

**Toshifumi ISE,
Hiroaki KAKIGANO
(Osaka University, JAPAN)**



Outline of the Presentation




1. Introduction
2. System Configuration and Control Scheme
3. System Configuration for Loss Calculation
4. Data for Loss Calculation
5. Results of Loss Calculation
6. Conclusions



1. Introduction

Low Voltage Bipolar Type DC Microgrid



Features of Proposed DC Microgrid



1. The distribution of load side converters provides super high quality power supplying.
2. Various forms of electric power like single phase 100 V, three phase 200 V, DC 100 V can be obtained from the ± 170 V DC line.
3. Rapid disconnection and reconnection with the utility grid are realized easily.
4. Electric power can be shared between load side converters.


2. System Configuration and Control Scheme

System Configuration



DC Microgrid for Residential Complex

All residences have their own distributed generations and share each other's electrical power.





All cogenerations are controlled by on/off operation. Then, total power from the generations can be calculated by a number of operating generations.

Power Management Scheme : Interconnected Mode





Interconnected operation mode




Power Management Scheme: Islanding Mode




Islanding operation mode




Configuration of Experimental System





- The experimental system consists of 3 houses.
- EDLC was chosen as an energy storage.



Appearance of the System



System setup



Gas engine cogeneration
(Rated Capacity 1 kW)

Experiments




System stable operation was confirmed by the experiments as follows:

- Fundamental system characteristics
(Load variation, Operation of DGs,
Voltage sag, Short Circuit at the load side)
- Power Supplying to real home appliances
- Control method of operating DGs' amount
- Disconnection from and reconnection with the utility grid

In this presentation

- Voltage clamping control is mentioned.
- The experimental results are shown.


Control of EDLC in Interconnected Mode




Effect of Voltage Clamp

1. Keep distribution voltage if the current of rectifier is limited.
2. Prevent over voltage of the devices connected to dc line
3. Help disconnection and reconnection process







Control Scheme of Disconnection



1. Stop rectifier when problem is detected
2. Start clamp control of EDLC converter
3. Change to constant voltage control




Experimental Results of Disconnection




Seamless disconnection was verified when blackout occurred.







Control Scheme of Reconnection



1. Detect the voltage of utility grid
2. Change EDLC to clamp control
3. Start voltage control of rectifier




Experimental Results of Reconnection




Smooth reconnection was verified when utility grid was recovered.

Experiment of Voltage Sag



Experimental Results of Voltage Sag



The voltage sag did not make
the system disconnect.
→ Fault ride-through operation

3. System Configuration for Loss Calculation

Objective of this Research




Loss comparison between ac microgrid and dc microgrid

Losses were calculated by

- Load data measured in a residential complex
- PV output data estimated by global solar radiation and temperature of a PV panel

Those are whole year data
measured by Osaka University.




Size of Target Residential Complex



PV : 30 kW


Gas
Engine
6.6 kW




5 houses on a floor

〔 Size is referred to a real residential complex in Japan 〕


Distribution Line Configuration (AC)




Distribution Line Configuration (DC)



Composition of Each House (AC)



Composition of Each House (DC)




Example of Load Converter Efficiency



Refrigerator and Washing Machine


AC System



Efficiency

92 %

DC System




95 %

4. Data for Loss Calculation

Total Electric Power Consumption




20 houses data (measured in a residential complex)




Hot-water Consumption



20 houses data (measured in a residential complex)



Output Data of PV System



The error of total generation energy is **-1.9 %**.


Converter Efficiency for PV Panel



Rated Capacity is 30 kW.

PV is controlled under MPPT control.


Output power can be flown to the utility grid.



Converter Efficiency for Grid Interface (DC only)



Rated Capacity is 80 kVA (= 4 kVA x 20 houses).
A chain link type multilevel converter is assumed
because of its high efficiency.



5. Results of Loss Calculation

Loss calculation was carried out under following conditions.

Calculation step: 30 min, Period : 1 year

- Load (electricity, heat, common lights)

Averaged data were used in each month.


- PV output (30 kW)

Estimated data (365 days) were used.


- Gas engine (6.6 kW)

The operation was determined from heat demand.

DG Output Energies and Consumption




Total Losses




Losses of the dc system are around **15 %** lower than that of the ac system for one year.

Loss Reduction Ratio



The loss reduction ratio is higher than 16 %.

Details of AC & DC System Losses



The distribution losses are negligible in both systems.

6. Conclusions

Conclusions(1)



- The configuration and operation of a low voltage bipolar type dc microgrid for residential houses was proposed.
- The experimental results by a laboratory scale model demonstrated the system's steady operation when the system was disconnected from and reconnected with the utility grid.
- The experimental results demonstrated dc microgrid was stable against voltage sags, and the fault ride-through operation was also realized by the proposed operating scheme.

- The losses of ac and dc microgrid for residential complex are compared.
- The simulation results show that the whole losses of the dc system are around **15 % lower** than that of the ac system for a year.
- If the energy storage is included, it is expected the loss reduction effect of dc distribution becomes higher than this result.