

Microgrid And Smart Grid Activities At SMUD

Presented by

Mark Rawson

Senior Research Project Manager

Energy

Research and Development
Program

Sacramento Municipal Utility District

**2010 Microgrid Symposium
July 2010**



SMUD

SACRAMENTO MUNICIPAL UTILITY DISTRICT


The Power To Do More.SM

Presentation Topics

- SMUD Microgrid Definition
- Drivers For Project
- Project Overview
- Demonstration Site Features
- Modes of Operation
- Major Equipment
- Customer Economic Feasibility
- Schedule Going Forward
- Future Additions

SMUD's Microgrid Definition

- A Smart Grid concept
- “Integrated energy system consisting of interconnected loads and distributed energy resources which as an integrated system can operate in parallel with the grid or in an intentional island mode”
- Microgrids can vary in scope, size, and ownership



Source: US DOE/CEC Microgrids Research Assessment, Navigant Consulting Inc., May 2006

SMUD project will demonstrate multi-facility scale microgrid.


Board Policy and Customer Drivers For Microgrid Demonstration

- Supports Board strategic directives
 - SD-4 Reliability
 - SD-7 Environmental Protection
 - SD-9 Resource Planning
 - SD-10 Research and Development
- Invests in R&D to:
 - Improve customer and system reliability at reduced cost
 - Reduce peak load
 - Reduce Ghg through more efficient use of NG
 - Develop and deploy cost effective, clean distributed generation

SMUD Microgrid Project Overview

310kW demo of CEC/DOE/CERTS Microgrid concept
for our central utility plant

- California Energy Commission funded project - \$2.9M over 3 years
- Partners include DE Solutions, TecoGen, NREL, CERTs, Univ. of Wisconsin
- Real world performance
- Integration and interoperability with demand responsive load control, advanced reciprocating engines, PV, and thermal energy storage
- Seamless separation and isolation from utility grid and resynchronization
- Feeder peak load reduction
- Economic value to customers and utility
- Technical and operational distribution system implications of exporting power from a microgrid




Existing Central Utility Plant


- Serves HQ buildings with chilled and hot water for space conditioning
- Equipment
 - Two centrifugal chillers
 - 600 tons and 200 tons
 - Efficiency 0.7 kW/ton
 - Two boilers
 - Two 5 MMBTUh hot water heaters
 - Two 1 MMBTUh hot water heaters
 - 80% efficiency
 - 760,000 gallon (15,000 ton-hr) Thermal Energy Storage (TES)




Thermal Loads



Cooling Loads





Grid Connected Operation

- Connected to 21 kV Feeder supplying loads in the CUP and FRF
- Excess electricity exported back to grid
- Priority thermal given to space heating and cooling will be secondary
 - Existing heating system is shut off between May and September
- When cooling, CHP system absorption chiller will charge TES tank
 - Absent heating load, absorber dispatched 24/7 for this purpose
- Tecogen INV-100 units will conservatively have a 92 % availability factor
- Absorption chiller sized to operate off recovered heat from two or all three INV-100 units
 - Should only one INV-100 be in operation, the absorption chiller will not be designed to operate
- System will include dump radiator to enable full-load CHP system operation regardless of the demand for heat

Islanded Operation

- Microgrid CHP system will “seamlessly” transition to islanding mode during grid disturbance
 - Non-critical loads in the CUP/FRF will be tripped
 - Noncritical loads include electric chillers and yet to be determined select air conditioning loads in FRF
- Remaining sensitive and critical loads will be prioritized and tripped off line as required (load shedding)
 - Must be tripped instantaneously to avoid under frequency tripping of INV-100s
 - Load shedding not likely needed unless one or two engines are down
 - Load shedding details are to be determined
- CUP will be served from three INV-100 units through a 480 volt bus
- 480v to 12 kV step-up transformer used to power FRF
- Recovered heat used in like-fashion to grid connected mode
- Smart Switch will automatically resynchronize microgrid when feeder is reenergized

TecoGen CHP Systems

- First engine driven product with UL certification for “utility safe” interconnection
- First product to commercially offer CERTs controls algorithms for microgrid operation (Droop control)
- Features:
 - Low emission NG engine
 - Water-cooled permanent magnet generator
 - Operated over wide speed range to optimize fuel efficiency
 - Power electronics converts variable frequency to 60 Hz
 - 700,000 BTU/h recoverable heat
 - 82.4% (LHV) overall efficiency
 - Provides 230°F hot water




Figure 2 – The INV-100 Advanced Power Generation Technology


Thomas & Betts Cyberex Smart Switch



- SuperSwitch₃ by Cyberex
- Digital Power Static Transfer Switch
- Features:
 - 600 Amps
 - 480 V, 3-Phase, 3 wire + gnd, 60 Hz
 - 1 Bypass Switch
 - 100 kA withstand
 - Hockey Puck Style SCR (Type – II)
 - Comprehensive metering, monitoring, control and alarms
 - Color LCD Display
 - Remote and Local Control, and Bypass
 - Incorporates proprietary CERTs Smart Switch controls



Thomas & Betts Cyberex Smart Switch (cont'd)



Absorber

- Specification for bids completed but equipment not yet selected
 - Broad, Carrier/Sanyo, Century/Cention, JCI/York, Trane/Thermax, Yazaki
- Features:
 - Single-stage low temperature hot water absorption chiller
 - 120 tons cooling capacity
 - 2,100 MBH total energy input
 - 210°F hot water input
 - 180°F hot water output
 - 52°F chilled water input
 - 42°F chilled water output
 - Automatically controlled with alarming

Project Economics

Commercial type application would be favorable
given high heat utilization factor


<u>EIA Gas Price Projection and Electric Price Escatation</u>										
	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019
Fuel Costs	(\$140,505.13)	(\$149,782.02)	(\$154,872.44)	(\$158,242.81)	(\$165,796.22)	(\$174,156.03)	(\$183,848.88)	(\$193,880.48)	(\$204,931.41)	(\$218,156.78)
Electric Revenues	\$223,948.65	\$225,768.45	\$231,148.32	\$234,965.56	\$238,935.49	\$241,266.66	\$245,499.15	\$249,931.20	\$254,409.14	\$259,199.51
Thermal Savings	\$37,086.47	\$39,203.83	\$40,340.81	\$41,241.82	\$43,044.11	\$45,169.81	\$47,454.55	\$49,811.94	\$52,415.20	\$55,472.02
Total Savings	\$120,529.99	\$115,190.26	\$116,616.69	\$117,964.57	\$116,183.38	\$112,280.44	\$109,104.82	\$105,862.66	\$101,892.93	\$96,514.75
Capacity Factor	75.9%	75.2%	75.9%	75.9%	75.9%	75.2%	75.2%	75.2%	75.2%	75.2%
	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Fuel Costs	(\$231,296.11)	(\$242,928.73)	(\$253,609.11)	(\$255,339.37)	(\$262,871.88)	(\$266,635.07)	(\$277,556.17)	(\$293,036.55)	(\$312,117.24)	(\$324,552.97)
Electric Revenues	\$262,356.08	\$265,771.89	\$272,853.41	\$280,134.22	\$286,183.52	\$292,402.64	\$298,710.83	\$305,104.61	\$311,922.79	\$316,877.13
Thermal Savings	\$58,580.91	\$61,651.19	\$63,837.69	\$64,406.00	\$66,220.59	\$67,242.80	\$69,840.64	\$73,457.58	\$77,827.80	\$80,865.48
Total Savings	\$89,640.88	\$84,494.35	\$83,081.99	\$89,200.85	\$89,532.23	\$93,010.37	\$90,995.30	\$85,525.64	\$77,633.35	\$73,189.64
Capacity Factor	74.5%	73.9%	74.5%	75.1%	75.2%	75.2%	75.2%	75.2%	75.2%	74.5%
NPV @ 6%	\$1,180,561.27									
Total Cash	\$1,968,445.09									

Schedule

- Detailed Design August 2010
- Smart Switch Pre-commissioning Q4 2010
- Construction Q1 2011
- Commissioning Q1 2011
- Demonstration Q2 2011 – Q3 2012
- Final Reporting Q4 2012

Future Additions

ARRA FOA 36 Topic 2.3: Regional Smart Grid Demonstrations



- Partners include Premium Power, National Grid, SAIC, NREL, Syracuse University
- Will firm renewables, reduce peak load and cost to serve peak, and improve reliability
- Installing two 500kW – 6 hours systems
- Operating as a fleet of distribution assets
- Quantifying costs and benefits of this storage deployment to gain insights to broader application for SMUD

Benefit	Metric	Sacramento Fleet
Peak load reduction	Peak Load	5-10%
T&D loss reduction	T&D Losses	2%
Reduced cost of power interruption	CAIDI/SAIDI/SAIFI improvements	10%
Reduced damages as a result of lower GHG/carbon emissions	MWh served by renewable sources	TBD
Reduced cost to serve peak energy (energy arbitrage)	Hourly marginal cost data	70%