Overview of Microgrids in Europe

Developments in system operation and research and test facilities





Niagara 2016 Symposium on Microgrids 20-21 October 2016 Niagara-on-the-Lake, Ontario, Canada

Presenter: Wolfram Heckmann, Fraunhofer IWES, Kassel, Germany



Overview of Microgrids in Europe

- Developments in system operation
 - Web-of-Cells approach of the Electra project
 - Remote areas
 - Continuity of supply
- Research and test facilities
 - DERlab
 - Summary of projects and facilities of DERlab members in Europe
- Annex
 - Detailed description of microgrid projects and test facilities of DERlab members



Web-of-Cells – Approach of the Electra project




Web-of-Cells Concept



Decentralized control scheme for future reserves

activations based on local observables : solving local problems locally



- Load Frequency Control Areas → smaller cells that are responsible both detecting the need for reserves activations as well as for the reserves activation itself
- Local collaboration between cells based on local observables instead of global collaboration based on frequency as global observable

CIRED Side Event 15-Jun-2016, HelsInkl

Web-of-Cells – Approach of the Electra project



Trends and Challenges



 From: Transmission grid connected dispatchable synchronous generators with downstream power distribution ('copper plate')



To: Large number of small intermittent generators that are distributed everywhere (all voltage levels)

- Increasing electrical loads (at medium/low voltage levels)
- Active control of flexible loads



Reverse powerflows, local congestions, local voltage problems


CIRED Side Event 15-Jun-2016, Helsinki

Web-of-Cells Concept



Helsink

June



Divide-and-conquer : computational tractability and communication/aggregation complexity and cost

- Solve local problems locally based on local observables, acknowledging that:
 - Causes are highly distributed and local
 - Resources that can solve are local.
 - Detailed local information is needed to active securely and effectively
- Instead of : Bottom-up / computation challenge / top-down
- > Voltage : obvious
- System Balance : restore as aggregated effect of restoring local balances
 - I neal halance as in 'l G'
 - Local balance as in 'adhere to your import/export profile' (cfr FRC): tieline powerflows: responsibilizing, 'the polluter pays'


CIRED Side Event 15-Jun-2016. Helslnkl





Web-of-Cells – National adaptation

- VDE-ETG study "Der Zellulare Ansatz" ("Cellular Approach")
 - Combined cells of information, power, and heat
 - New options for system operation
 - Provision of ancillary services
 - Temporarily self-sustaining operation (especially for residential, commercial, and small industrial areas)
 - Summing-up of cells horizontally and vertically
 - Island operation in emergencies




[VDE-ETG 2015]




Remote areas - Project examples from Germany and Greece

Off-grid industrial sites



- PV-Diesel-Battery systems up to some MW for off-grid applications
- https://www.solarstromforschung. de/pv-diesel/

Geographic islands



- Agios Efstratios RES Electrification system including H2
- aiming at 100% RES and not less than 85% of the annual demand

Continuity of supply – Contribution from microgrids

- Objectives and benefits of microgrids
 - to serve particularly sensitive loads such as emergency service
 - to use local assets difficult to operate by the centralized grid
 - to present a controlled profile to the wider power system

... the intent is that a microgrid can function for more than a few minutes as a controlled electrical island.

MICROGRIDS 1 ENGINEERING, ECONOMICS, & EXPERIENCE

VG C6 22 Microgrids Evolution Roadman

Working Group Contributors

C. Mamay (US), Convenor, with C. Abbey (CA) & G. Joos (CA), Secretaries. K. Ach (AU), S. Bando (IP), M. Frann (DE), S. Chatrizuelleades (US), J. Drisson (BE), N. Hattiargriou (GR), R. Iravani (CA), G. Jimenes (CL), F. Katirasi (CA), P. Lombardi (DE), K. Lynch (IE), P. Mancarella (UK), D. Moneta (IT), C. Moreira (PT), A. Oudalov (CH), M. Thattaib (IP), F. Manic (IP), M. Thattaib (IP), T. Manil (IP), M. Thattaib (IP), T. Manil (IP), M. Thattaib (IP), T. Shail (IP), B.

Copyright © 2015

"Ownership of a CIGRE publication, whether in paper form or on electronic support only infers right of use for personal purposes. Unless explicitly agreed by CIGRE in writing, total or partial reproduction of the publication and/or transfer to a third party is prohibited other than for personal use by CIGRE individual Members or for use within CIGRE Collective Member organizations. Circulation on any intranet or other company network is forbidden for all persons. As an exception, CIGRE Collective Members are allowed to reproduce the publication only.

Disclaimer notice

"CIGRE gives no warranty or assurance about the contents of this publication, nor does it accept any responsibility, as to the accuracy or exhaustiveness of the information All implied warranties and conditions are excluded to the maximum extent permitted by law".



ISBN: 978-2-85873-338-5

→ Supply critical infrastructures/ emergency centers

[CIGRE 2015]

- Bridge the black-out after a break down until the system is restored
- → Use of defined and stable loads, e.g. for network restoration procedures



Continuity of supply – Supply islands in cities

- Civil protection in long-lasting black-outs, i.e. days to weeks
 - Supply of the inhabitants by protection & security forces like fire brigade and technical services with mobile diesel gen-sets
 - Support of the protection & security forces by structures not relying on the connection to the transmission grid
 - First priority: safeguard vitally important services like water supply or emergency center
- Building supply islands in German cities
 - Coverage of municipal islands often about 50% of regular interconnected operation
 - Time to build-up the island network 2-6 hours (others sources 10-12 hours)




[Höser 2015]




Continuity of supply – NETZ:KRAFT project "HV-island"

- Feed-in grid with wind parks supplying a load center
 - Failure of the transmission system (380 kV)



Continuity of supply – NETZ:KRAFT project "MV-island"

- PV and biomass to start islands from LV and extend to MV
 - Failure of the high voltage system (110 kV)



Concept

- Start with mobile diesel gen-set, include PV
- 2) Extend to MV line
- 3) Activate biogas plant
- 4) Extend supply to further villages



Overview of Microgrids in Europe

- Developments in system operation
 - Web-of-Cells approach of the Electra project
 - Remote areas
 - Continuity of supply
- Research and test facilities
 - DERlab
 - Summary of projects and facilities of DERlab members in Europe
- Annex
 - Detailed description of microgrid projects and test facilities of DERlab members



DERlab - European Distributed Energy Resources Laboratories e.V.

 Over thirty institutes from Europe and U.S. performing research related to Smart Grids (SG) integration of Distributed Energy Resources (DER)

13

- Accredited testing of DER-units and smart grid equipment
- Support of smart grid development and integration of renewable energies
- Organisation of information and knowledge exchange on testing infrastructure
- Contribution to standardisation activities
- The association's research laboratory infrastructure offer the necessary expertise and equipment for DER in a coordinated manner



www.der-lab.net




DERlab - Methods and Techniques









Full scale testing of DER components

- Lab capabilities up to the MVA range, LV to HV
- Dedicated facilities for all RES technologies
- Compliance testing and validation of all grid relevant functions
- Performance, safety and reliability

Lab and field testing of DER systems

 Testing and validation of power system (ancillary) services from distributed units

Interoperability and communications

- Laboratory platforms able to test the interoperability between DER units
- Testing of communication interfaces according to international standards

14

Power and Controller Hardware in the Loop (PHIL/CHIL)

- Synthesis of simulation and hardware experiments
- Allows equipment to be validated in a virtual power system



Projects and facilities of DERlab members in Europe

- Microgrids Research Infrastructures
 - Small scale laboratory level:


MicroDERlab (RO), AIT (AT), LEMKO (BE), TUS-RDS (BG), HES-SO (CH), FOSS (CY), KIT (DE), SEER (ES), TECNALIA (ES), VTT (FI), G2Elab (FR), RSE (IT), DNV GL(NL), TU Lodz (PL), Uni. Manchester (GB) and INESC Porto (PT).

Large scale laboratory level:

Fraunhofer IWES, DTU (DK), CIEMAT (ES), Uni. Sevilia (ES), NTUA (GR), CEA-INES (FR) and Uni. Strathclyde (GB).

Demo site level:


EDF – Concept Grid –France and CRES – Microgrid Pikermi – Greece.






Small scale laboratory level examples: INESC Porto

- DC/AC microgeneration prototypes
 - Main functionalities:
 - Single-phase DC/AC inverters.
 - Solar inverter with MPPT power adjustment.
 - Active power control for voltage grid support.
 - Bi-directional communication with the MGCC.
 - Possibility of remote control.
 - Experimental Objectives:
 - Grid support by new voltage control strategies
 - Smart grid control and management architecture.









Large scale laboratory level: Fraunhofer IWES – SysTec Testing Field Hybrid Systems

Testing operation in smart low voltage grids



Large scale laboratory level: Fraunhofer IWES – SysTec Testing Field for Hybrid Systems


Medium voltage test grid and hybrid system test bench



Demo site level: CRES

- Agios Efstratios Green Island National project
 - Planning 100% RES penetration
 - Permanent population: 210
 - The population more than doubles for 1-2 months during summer
 - Wind: 600-800 kW
 - PV sys.: 150-250 kWp
 - Energy Storage: 3000-5000 kWh
 - Water electrolyser for H2 100 kW
 - Compressed Hydrogen Storage Tank of 200 kg of H2
 - Hydrogen-driven Genset 100 kW
 - Central Control and Data Acquisition System







Detailed description of microgrid projects and test facilities of DERlab members

- CIEMAT, Spain
- University of Seville, Spain
- National Technical University of Athens, Greece
- Technical University Sofia, Bulgaria
- Lodz University of Technology, Poland
- FOSS Research Center for Sustainable Energy, Cyprus
- CRES, Greece
- INESC TEC, Portugal
- Fraunhofer IWES, Germany





Overview of Microgrids in Europe

- Developments in system operation
 - Web-of-Cells approach of the Electra project
 - Remote areas
 - Continuity of supply
- Research and test facilities
 - DERlab
 - Summary of projects and facilities of DERlab menuers in Europe
- Annex
 - Detailed description of microgrid projects and test facilities of DERlab members



Contact



Wolfram Heckmann
Project Management
+49 561 7294-126
wolfram.heckmann@iwes.fraunhofer.de
www.energiesystemtechnik.iwes.fraunhofer.de





Research Coordinator
Dr. **Mihai Calin**mihai.calin(at)der-lab.net
Phone: +49 561 7294 483

References **CIGRE 2015** CIGRE Working Group C6.22, "Microgrids 1 Engineering, Economics, & Experience", Technical Brochure 635, cigré, Paris, Frankreich, Oktober 2015 Höser, Th., "Städtische Stromversorgung während eines langanhaltenden Stromausfalls", Bevölkerungsschutz Höser 2015 04/2015, Bundesamt für Bevölkerungsschutz und Katastrophenhilfe, Bonn, Deutschland, 2015 **VDE-ETG 2015** ETG Task Force Grundsätzliche Auslegung neuer Netze, "Der Zellulare Ansatz", Studie der Energietechnischen Gesellschaftt im VDE (ETG), Frankfurt, Deutschland, Juni 2015 http://www.electrairp.eu/index.php Electra **NETZ:KRAFT** http://forschung-stromnetze.info/en/projects/grid-restoration-with-future-power-plant-structures/ **DERlab** http://der-lab.net/



Overview of Microgrids in Europe

- Developments in system operation
 - Web-of-Cells approach of the Electra project
 - Remote areas
 - Continuity of supply
- Research and test facilities
 - DERlab
 - Summary of projects and facilities of DERlab members in Europe
- Annex
 - Detailed description of microgrid projects and test facilities of DERlab members



Detailed description of microgrid projects and test facilities of DERlab members

- CIEMAT, Spain
- University of Seville, Spain
- National Technical University of Athens, Greece
- Technical University Sofia, Bulgaria
- Lodz University of Technology, Poland
- FOSS Research Center for Sustainable Energy, Cyprus
- CRES, Greece
- INESC TEC, Portugal
- Fraunhofer IWES, Germany



Large scale laboratory level: CIEMAT Expertise in the Microgrid Research Topic




- Activities related to DER
 - Research
 - Testing
 - Pre-standardization
 - (Small) wind
 - PV
 - Fuel Cells
 - Kinetic energy systems
 - Microgrids

- Activities on Microgrid research
 - SINTER Project
 - GEBE Project

3

HIBEOSOLEO Project



Large scale laboratory level: CIEMAT Experimental Facility for Testing



Electrical

- Several buildings, operating as loads
- Transformers
- Renewable generators (solar 15kW, wind 100kW, 30 kW minihydro)
- Diesel generator set (50 kVA) with a clutch
- Storage systems (100+50 kWh Lead-acid, 50 kWh Li-ion, flywheel, hydrogen, supercapacitors)
- Dump load (40 kW controllable loads)

Communication

- distributed cable and OF network
- Monitoring & smart-meter network

■ Cold / Heat

- central district-heating and
- controllable 100kW electric boiler

Hydrogen

- biomass gasifier and
- some H2 loads



Large scale laboratory level: CIEMAT















Large scale laboratory level: University of Seville MV/LV research lab



■ One-line Diagram



■ MVL Transformers




■ 0.5 MVA B2B VSCs





Large scale laboratory level: University of Seville MV/LV research lab






- Testing capabilities
- LV devices:
 - Hardware:
 - D-STATCOM
 - VSC for PV plants
 - BESS
 - Software:
 - Advanced control algorithms for PE devices
 - MV devices:
 - Distribution OLTC



Large scale laboratory level: University of Seville Active distribution networks research lab

8






CIGRE task force C06.04.02

Actual German distribution network to analyse the impact of DG including:

- DG (PV, wind, CHP)
- Energy storage systems
- Industrial/residential loads
- Flexible links between radial feeders

Large scale laboratory level: University of Seville Active distribution networks research lab





Large scale laboratory level: University of Seville Active distribution networks research lab




Scaled-down distribution network



- Testing capabilities
- DG Integration in MV systems:
 - Modification of power flows
 - Voltage profiles
 - Losses
 - Impact of storage systems
- New tools for DMS:
 - Distribution state estimation
 - Volt/Var control
 - Centralized control of DG
- Advanced control algorithms for:
 - Renewable power plants
 - Storage systems



Large scale laboratory level: Microgrids at NTUA







Large scale laboratory level: Microgrids at NTUA LV Microgrid and Hardware-in-the-Loop environment



LV Microgrid

RTDS Power Amplifier



Large scale laboratory level: Microgrids at NTUA


LV Microgrid and Hardware-in-the-Loop environment




Heckmann, 2016 Symposium on Microgrids

Large scale laboratory level: Microgrids at NTUA Centralized Secondary control of Microgrid for frequency regulation

- Islanded microgrid consisting of PV generation, storage and controllable loads
- The battery inverter operates in droop mode, varying the microgrid frequency according to its output power






(b)

a) Laboratory setup for frequency restoration, b) Measurement of the frequency droop curve.

Large scale laboratory level: Microgrids at NTUA Centralized Secondary control of Microgrid for frequency regulation

■ To restore the frequency back to the nominal value (50Hz), the frequency deviation is measured at each time-step and the droop curve is changed by a setpoint sent to the battery inverter



Active power and frequency of the microgrid with secondary frequency control



Large scale laboratory level: Microgrids at NTUA Decentralized Secondary control in an Interconnected Microgrid

- DG units and load controllers are equipped with a certain level of autonomy in making decisions about the energy management of the microgrid.
- Applications:
 - Market participation of the Loads or the DG/RES
 - TCP/IP

 Computer

 Agent

 Agent

 Agent

 Agent

 Agent

 Agent

 Agent


 Agent

 Agent

 Agent


Large scale laboratory level: Microgrids at NTUA Islanded microgrid at a PHIL configuration

Hardware PV inverter: 1kW single phase with over-frequency droop






Large scale laboratory level: Microgrids at NTUA Islanded microgrid at a PHIL configuration



Large scale laboratory level: Microgrids at NTUA Hardware-in-the-loop testing chain for DC Microgrid operation



 Control Hardware-in-the-loop infrastructure for testing Islanding detection methods on DC microgrids






Large scale laboratory level: Microgrids at NTUA Hardware-in-the-loop testing chain for DC Microgrid operation




■ Power Hardware-in-the-loop infrastructure for testing Islanding detection methods on DC microgrids





Large scale laboratory level: Microgrids at NTUA

Hardware-in-the-loop testbed for AC Microgrid centralized and distributed control strategies







Power Electronics Laboratory

- Hybrid installation consists of a LV microgrid, Including, two SMA inverters, storage, controllable AC loads Chroma AC 63802, monitoring with Internet connection, Network connected and Island operation.
- In April 2012 Installation was equipped with a SCADA and SIMENS PLC based Control System.










Power Electronics Laboratory




- Dr. Anastassia Krusteva
- Dr. Metody Georgiev
- Dr. Rad Stanev
- with co-support of Prof. D.Sc Michail Antchev





■ Power Electronics Laboratory







Power Electronics Laboratory


- Six PV units Sharp NT175
- PV inverter SMA Sunny Boy 1200
- SMA Sunny Island 2224 (grid-forming)
- Batteries CSB GPL121000 (12V, 100Ah)
- Controllable load Chroma AC 63802
- Windows-based computer with Internet connection
- SCADA control system and electrical connections remote monitoring and control of microgrid regimes were realized.
- Experimental regimes:
 - Normal Operation Mode (grid and PV are connected) NOP
 - Grid Operation Mode (without PV generation) GOM
 - Island Operation Mode landed, with PV generation) IOM
 - Batteries Operation Mode (islanded, without PV generation) BOM.
- JaNDER Gateway is installed in TUS-RDS PEL ensuring connection using IEC 61850 client and/or Web Browser.



Small scale laboratory level: TU Sofia R&DS Microgrid remote control and testing



"Smart Buildings and Renewable Energy Integration in Micro Grids"







The Laboratory of Distributed Generation (LDG) is loacated in Institute of Electrical Power Engineering at Lodz University of Technology. LDG serves for testing the integration of distributed generation with the power networks. This laboratory is designed to build, simulate and test microgrids and its interoperability with the power networks.

27



Sun tracking PV system 9 kWp





Research Fields

- quality of supply in distribution networks with distributed resources,
- application of energy storages for energy management and power quality improvement,
- management and control systems for microgrids,
- autonomous operation of microgrids,
- integration of EVs with electrical power grid.


■ Technical Infrastructure

- renewable energy sources,
- energy storage systems (including emulator of electric vehicle charging hardware),
- energy sources utilizing traditional fuels,
- supplementary devices supporting microgrid,
- digital real time simulator RTDS with power amplifier.





General structure of laboratory





- Research capabilities of Laboratory of Distributed Generation:
 - implementation and testing of strategies and algorithms for microsystems management
 - utilization of energy storage systems with renewable energy sources,
 - DSM algorithms
 - use of power sources and ESS inverters to compensate the electromagnetic disturbances: voltage fluctuations, distortion and asymmetry currents
 - use of renewable sources and energy storage system to compensate the voltage dips
 - microsystem management during the autonomous operation


- Features of laboratory infrastructure
- State of the art equipment the possibility and necessity to solve practical problems
- Flexible structure and configuration the ability to build customized microsystems
- Versatile measuring and controlling systems
- Remote access to the measurement and control systems - the ability to perform research in the periods determined by environmental conditions
- Simultaneous operation of several electrical networks



Small scale laboratory level: TU Lodz Tests capabilities using RTDS



- Versatile tests utilizing the Real Time Digital Simulator:
 - Hardware in the Loop
 - Software in the Loop




Different setups for Hardware in the loop tests




Small scale laboratory level: TU Lodz Cogeneration system



■ Microturbine Capstone C30



- Electrical power putput: P_{el} = 30 kW
- Thermal circuit output:P_{ci} = 60 kW



■ Microturbine control over SCADA

Small scale laboratory level: TU Lodz Versatile Energy Storage Systems with Customized Inverter




ABB



■ PCS100 ESS

Parametr	Unit.	AGM batteries	Vycon Flywheel	Super- capacitors
Nominal power	kW	50	350	300
Energy	kWh	50	0,68	0,65
DC voltage	V	520	520-540	300-600
Discharge time (nominal power)	s	3600	7	7
Rotating speed	rpm		38000	
Capacity	F			12,5





Small scale laboratory level: TU Lodz Tests Examples utilizing Energy Storage System



■ Microturbie Capstone C30

- Integration with RES:
 - storing energy in periods of excess power production
- Load leveling
- Managing of peak loads
- Load shifting

Ancillary Services

- Uninterruptable power supply during voltage sags and power interruption,
- Compensation of electromagnetic disturbances (improving of electrical power quality)



Small scale laboratory level: Cyprus University Research Center for Sustainable Energy (FOSS)



- Cyprus university campus is transforming into a truly living lab with state of the art technologies and sources capable of operating as a microgrid control area.
- A planned fully functioning microgrid infrastructure A test bed for related technologies and systems for research, development, training and education
- Already erected or planned to be erected:
 - Local PV generation directly connected to the local grid (350 kWp already connected and operated as self-consumption – 10 MWp to be operational by December of 2017).
 - 1 MWhr electrochemical storage facilities (2017) that will increase load management capabilities, improve operational capabilities and offer services to the local DSO
 - 1 MW thermal equivalent system of 4 heat pumps for the planned extensions of the university
 - Smart meter facilities capable of offering valuable data and local control for the development of demand side management and demand response
 - Full broad band connectivity with the local DSO using fibre optic cables and PLC
 - A smart energy management system for demand scheduling and control

Coming:


Additional smart sensors and distributed controllers for completing the smart microgrid architecture including island networks within the university campus capable of facilitating targeted research work without affecting the rest of the campus. All to be completed by 2020 ...



Demo site level: CRES Microgrid, Pikermi, Greece

KATIE CRES

System Diagram




Demo site level: CRES Microgrid, Pikermi, Greece

Configuration

- 2 Photovoltaic arrays (1,1 and 4,4kWp)
- 2 Battery storage systems (40 kWhs each)
- 1 Diesel generator (12,5kVA)
- 1 PEM Fuel cell (5kW)
- Controllable load bank (13kW)
- Interconnection to public grid
- Data Acquisition and contol using interbus
- Supervisory control console developed in LabVIEW















Demo site level level: CRES DERri Transnational Activities projects



Carbon Agents for Virtual Power Plants

Implementation and testing of a Multi-Agent System for the operation of a VPP in terms of CO2 emissions. The project was done in cooperation with Cardiff University (UK) and ICCS/NTUA (GR).

http://www.der-ri.net/uploads/media/FactSheet-CA_VPP_GF_20120717.pdf

Stohastic Optimal Predictive Control for Microgrids

Implementation of a centralized Stohastic controller for the management of the microgrid in terms of energy market criteria. The project was done in cooperation with Sannio University (IT).

http://www.der-ri.net/uploads/media/FactSheet-SOPC_GF_20120717.pdf

Microgrid Stohastic Predictive Control

 Extension of the previous project considering also aspects such as thermal need coverage and CO2 emissions produced by the microgrid

http://www.der-ri.net/uploads/media/FactSheet-MSPC_GF_20120717.pdf





MIRABEL: Micro-Request-Based Aggregation, Forecasting and Scheduling of Energy Demand, Supply and Distribution (FP7)

- Development of approach that allows energy distribution companies to balance the available supply of RES and the current demand.
- Testing of the developed technology in CRES microgrid under two main scenarios:
 - Grid connected household community
 - Isolated Distribution Grid (Local Distributor of Energy-LDE)
- Test objectives
 - Assessment of developed product in terms of operation of its components (flex-offers, forecasting, aggregation, scheduling)
 - Evaluation of the overall performance in terms of energy balance,
 RES/conventional generation ratio, energy efficiency etc.

http://www.mirabel-project.eu/



KATE CRES


Gaidouromantra "islanded" Microgrid in Kythnos island, Greece





PROJECTS 1999- 2013

- 1. PV-MODE, JOR3-CT98-0244
- 2. MORE, JOR3CT98-0215
- 3. MORE MICROGRIDS, FP6 No. 019864








Gaidouromantra "islanded" Microgrid in Kythnos island, Greece

Objectives of the project:

- Design, implement and operate an inverter based electric power system powered from Photovoltaics offering basic quality electricity service
- Development of control and management techniques, for storage, PV generators and non-critical loads for reliable and effective operation
- Before 2001, there was no grid and 4 houses out of 12 had a diesel generator.
- The site was chosen because at the time it was far from the MV grid (5 km), now the closest MV pole is about 700 m away.










Gaidouromantra "islanded" Microgrid in Kythnos island, Greece



- 12 Vacation Houses
- 6 Distributed PV sys capacity 12.5 kWp
- 50 kWh Battery bank,
- Lead acid OPzS
- 9kVA Diesel genset
- 3-phase LV grid formed by 3 Sunny Island 5048 Inverters
- System Operation April 2001 to Present
- Change of Inverters in 2008
- Battery bank changed in October 2009

Demo site level: CRES Gaidouromantra "islanded" Microgrid in Kythnos island, Greece



- Further Work in Gaidouromantra, Kythnos island
 - CRES is responsible for continuing monitoring, servicing and maintaining the microgrid
- The following ideas are suggested for a future R&D project in Gaidouromantra microgrid, Kythnos Island:
 - Interconnection of the Gaidouromantra microgrid with the Kythnos island Medium voltage grid and optimization of the microgrid operation in islanded and inter-connected mode to make use of the excess PV energy.
 - Development of the required protection measures, communication and control of an active (bi-directional) Low Voltage - Medium Voltage transformer as well as ancillary services and business models.



KATE CRES

Agios Efstrations – Green Island National project

- Planning 100% RES penetration
- Permanent population: 210
- The population more than doubles for 1-2 months during summer


Wind: 600-800 kW

PV sys.: 150-250 kWp

Energy Storage: 3000-5000 kWh

- Water electrolyser for H2 100 kW
- Compressed Hydrogen Storage Tank of 200 kg of H2
- Hydrogen-driven Genset 75-100 kW
- Central Control and Data Acquisition System









DC BUS

Agios Efstrations – Green Island National project


The system operation simulation and comparison with historic electricity production cost data show that the implementation of a RES based power system for the island is cost effective, with a LCOE of less than half of the conventional diesel fuel powered system.

Existing Power System

45

Year or Scenario	Variabale cost of electricity in €/MWh	Fixed cost of electricity in €/MWh	Total cost of electricity in €/MWh
2002		-	373.46
2008	312	331.65	643.65
2010	225	331*	556
Scenario 1 (3.345 MWh/day)		-	200
Scenario 3 (3.345 MWh/day)		-	234
Scenario 5 (5.352 MWh/day)		-	199
Scenario 7 (5.352 MWh/day)		-	200

^{*:} Assuming that the fixed cost did not change between 2008 and 2010



Basic block diagram of Agios Efstratios RES Electrification system including Hydrogen components.



© Fraunhofer IWES

Conclusions




- Coincidence of seasonal peak of PV and Wind energy production in islands during the tourist high demand season in the summer
- Photovoltaic systems are complementing Wind turbines' energy production in Greek autonomous island Electric Systems up to annual RES energy penetration of about 15% without any control requirements
- In the annual RES energy penetration range from 15 to 25%, monitoring and sending operation set-points for control of wind parks' power output and next day forecasting of Wind and distributed PV plants (under 100 kWp) permits scheduling planning of thermal power plants for stable operation and voltage support in the LV grid, allowing sometimes RES instantaneous power penetration to exceed 60%.
- Further PV and variable renewable energy systems penetration in islands requires either connection to a larger electrical system such as the mainland system in Greece that works as a buffer for electricity flows and/or
- Integration of storage, demand response, generator production control and of course in parallel introduction of intelligence and communication applications in monitoring and controlling the grid, distributed resources and loads (i.e. Smart Grids)




Small scale laboratory level: INESC TEC MG as smart distribution cell



■ The MG is a flexible, active and controllable LV system, incorporating: Microgeneration, Storage devices, Electric vehicles








Small scale laboratory level: INESC TEC MG as smart distribution cell



Technical challenges – Integrated management of EV and RES





Small scale laboratory level: INESC TEC MG as smart distribution cell



- The MG can be regarded as the cell of future Smart Grids:
 - Enhance the <u>observability</u> and <u>controllability</u> of power distribution systems.
 - Actively integrate electric vehicles and loads in the operation of the system.
 - Increase the connection capacities for different distributed generation technologies.
 - Promote the coordinated management of microgeneration, storage, electric vehicles and load, in order reduce system losses and improve power quality.

49

<u>Provide self-healing capabilities</u> to the distribution network, due to its ability of operating autonomously from the main grid and perform local service restoration strategies.



Small scale laboratory level: INESC TEC Validation of MG operation concepts



Merge - Mobile Energy Resources in Grids of Electricity



- Main goals and achievements:
 - Development of a management and control concept that will facilitate the actual transition from conventional to EV.
 - Identify potential smart control approaches to allow the deployment of EV without major changes in the existing network and power system infrastructures.
 - To identify the most appropriate ways to include EV into electricity markets through the smart metering infrastructure.
 - To provide quantitative results on the impact of integrating EV into the grid of EU national power systems.

50

To provide computational suite able to identify and quantify the benefits that a progressive deployment of the MERGE concept will bring to the EU national power systems, taking into account several possible smart control approaches.



Small scale laboratory level: INESC TEC Validation of MG operation concepts



REIVE





- Study, develop and test of technical solutions and pre-industrial prototypes for the active and intelligent management of electricity grids with large scale integration of microgeneration and electric vehicles.
- Develop a technical platform which:
 - is able to identify and quantify the benefits of a progressive deployment of EV and microgeneration technologies.
 - includes innovative control solutions for microgeneration and EV systems.
- Development of a laboratorial infrastructure The MG and EV laboratory.
- Support industrial partners in order to deploy the technologies and products resulting from the concepts and prototypes developed.
- To propose a regulatory framework capable of:
 - integrating EV users in a fair and non-discriminatory way,
 - deal with the additional investments in the network control and management structures in order to reliably accommodate a large number of EV.





Main objectives:

- Development and testing of prototypes
- Development and testing of control devices and integrated management solutions
- Development of tests of communication solutions for smart metering infrastructures
- Testing EV batteries control and management
- Testing microgeneration control and management solutions
- Testing Active Demand Response and home area networks
- Developing and testing stationary storage and its control solutions for Smart Grids

52








Infrastructure











Electric infrastructure:

- Renewable based microgeneration
- Storage
- Resistive load bank 54 kW
- LV cables emulators (50 A and 100 A)
- Plug-in electric vehicles Renault Fluenze ZE and twizy
- Microgeneration and EV power electronic interfaces
- Electric panel, command and measuring equipment



25 kWh capacity Flooded Lead-Acid (FLA)



128 Lithium battery cells



15 kWp photovoltaic panels



3 kW wind micro-turbine





■ Infrastructure: commercial DC/AC microgeneration inverters



The two 25 kW FLA battery bank are connected to two three-phase groups of grid forming inverters – SMA Sunny Island inverters, enabling:

- Testing MG islanding operation.
- The inverters provide the voltage and frequency reference to the isolated system, based on P-f and Q-V droops.



The PV and wind turbine emulator can be coupled to the network through:

- Three DC/AC SMA Sunny Boy Inverters with 1.7 kW nominal power.
- DC /AC SMA Windy Boy Inverter with 1.7 kW nominal power.

The main objective is to explore the microgeneration commercial solutions and study potential limitations




■ Controllable microgeneration emulator - 4 quadrant AC/DC/AC inverter

56

- The laboratory is equipped with a 20 kW threephase AC/DC/AC custom-made four-quadrant inverter.
- The inverter power is controlled in order to emulate the response of controllable power sources such as Single-Shaft Microturbines or Fuel Cells.
- Enable the development and test of new frequency and voltage control strategies, in order to provide grid support during emergency conditions:
 - Microgrid islanded operation.
 - Microgrid restoration procedure.





IWES-SysTec Test Centre Smart Grids and E-Mobility

Outline:

- 1. Overview IWES-SysTec
- 2. Testing Laboratory Grid Integration (PNI)
- 3. Testing Centre for Electro-Mobility (TPE)
- 4. Testing Fields for Photovoltaic- and Hybrid-Systems
- 5. Applications
- 6. Services



Overview SysTec Test Centre Smart Grids and E-Mobility




Overview SysTec

Outdoor Facilities


- Photovoltaic Systems, Wind turbine Generators(planned), Hybrid Systems
- Electrical Test-Networks (LV,MV)

- Charge Infrastructure for E-Mobility
- Test track for inductive charging systems




2. SysTec - Testing Laboratory for Grid Integration (PNI) Electrical Setup

 Development- and Test Facility for quasi-stationary and dynamic testing of the grid interface of DER units and Systems (low- and medium voltage)



4. SysTec - Testing Fields for Photovoltaic and Hybrid Systems Testing integration into domestic homes / smart homes


- Representation of households / test houses
- 3 small buildings
 - roof integrated PV
 - electrical storage
 - heat pump
 - different household loads
 - charging stations for electric vehicles
 - energy management system
- 1 flexible test container "bring your own house"
- Measurement equipment








4. SysTec - Testing Fields for Photovoltaic and Hybrid Systems Testing operation in smart low voltage grids




4. SysTec - Testing Fields for Photovoltaic and Hybrid Systems Medium voltage test grid and hybrid system test bench



4. SysTec - Testing Fields for Photovoltaic and Hybrid Systems Medium voltage test grid (20kV)

Features

- Operation modes: Islanded or interconnected
- Two main substations interconnectable with different line lengths
- Physical network emulation for the representation of different line length (up to 30 km)
- Controllable loads
- Generation units: Diesel gen-set, PV inverter
- Electrical Storages: Pb and Li storage systems
- Space for additional customer systems





SysTec - ApplicationsActive and smart secondary sub-stations

- Application and tests of system concepts with different components
 - Controllable MV/LV transformers
 - Controllable PV-inverters
 - Local voltage stabilizer
 - Controllable loads and storages
- Well tuned system for dynamic voltage control
- Proof of concept and implementation by lab tests and pilot tests




Prototype of a controllable MV/LV transformer made by J. Schneider Elektrotechnik GmbH. Tests in SysTec for the Project "Aktives, intelligentes Niederspannungsnetz"



SysTec - Applications Active, intelligent LV networks

- Critical network conditions can be tested selective and reproducible
 - Configurable LV networks
 - Topology
 - Cable cross-section
 - Controllable Loads
 - Adjustable PV
- Validation of components and methods before operation in a real network with real customers
- Optimization of control algorithms
- Usage of HiL methods



Experimental setup of the project "Aktives, intelligentes Niederspannungsnetz".

