


Nikola Tesla

DC Power Distribution in Commercial Buildings




Thomas Edison

Why DC?

Technology and Market Trends

- DC-based distributed generation such as photovoltaic and wind
- On-site DC electrical storage
- The most efficient types of loads are natively-DC (LEDs, electronics, EV charging, induction stoves, and variable speed motors in HVAC and water heating)
- Power electronics
- DC Power Standards: USB, Ethernet
- Communications





Potential Benefits

- Energy Savings in Zero Net Energy (ZNE) Buildings with large solar and storage capacity
- Simpler power electronics: better cost and reliability
- Reliable microgrid islanding through power electronics allows for low-cost disaster resiliency
- Improved power quality
- Combined data and power allows for communications

Analysis Approach

AC vs. DC

Voltage Domains: 120V AC, 48V DC, 380V DC



Energy Simulation

- Develop Modelica models of AC and DC medium office building in Los Angeles
- Zero net energy building with all electric loads internally DC
- Solar profiles from PV Watts, and load profiles from EnergyPlus, and converter efficiency curves from product data
- Use parametric simulations to determine when DC is beneficial and by how much

Techno-Economic Analysis

- Determine first cost difference through product data and estimated quantity
- Determine operating cost from the energy simulation and CA electricity tariffs
- Estimate economic benefits of DC distribution with life cycle cost (LCC) and payback period (PBP)


Experimental Load Modification

- Modify common AC plug loads for a DC input
- Measure efficiency savings with DC
- Determine how each type of load should be modified to benefit most from DC

Results

Energy Simulation

- 12% baseline efficiency savings with DC
- More savings with high solar and battery capacity
- AC building loss is dominated by the poor efficiency of **load packaged rectifiers**
- DC building loss dominated by the **grid-tie inverter**



Techno-Economic Analysis

- Results determined from market cost data, grid tariffs, and Monte-Carlo analysis
- First cost is higher for DC
- Given the enormous efficiency savings, the payback period is less than a year
- End-use costs, installation costs, and other soft costs not considered

Description	Network	Average LCC Savings (US\$)
Total First Cost (\$)	AC	252,000
	DC	301,000
Net Annual Electricity Consumption (kWh/yr)	AC	177,000
	DC	101,000
Average LCC Savings (\$)	AC vs. DC	61,000
% Cases with Net Benefit	AC vs. DC	>90%
Average Payback Period (yr)	AC vs. DC	~1


$$LCC = \text{First Cost} + \sum_{y=1}^{\text{Lifetime}} \frac{\text{Operating Cost}(y)}{(1 + \text{Discount Rate})^y}$$
$$\text{Payback} = \frac{\text{First Cost}_{\text{DC System}} - \text{First Cost}_{\text{AC System}}}{\text{Operating Cost}_{\text{AC System}} - \text{Operating Cost}_{\text{DC System}}}$$

Experimental Load Modification


- Modified AC loads to take a DC input
- Demonstrated savings with DC input



Bath Fan (12%)



Refrigerator (1%)




LED Fixture (5%)



LED Zone Lighting (7%)

Future Research

- Develop detailed converter loss models to help compare AC and DC
- Develop a DC Design Tool to help building designers compare
- Field test upcoming and developed DC buildings



Xingye Solar Shenzhen



IBEW Building San Leandro



Marriott Sinclair Fort Worth



IBR Building Shenzhen

Daniel Gerber, Vagelis Vossos, Wei Feng, Richard Brown, Aditya Khandekar, Bruce Nordman & Chris Marnay

Lawrence Berkeley National Laboratory

We thank U.S. DOE and CEC for supporting this work!

Contact - dgerb@lbl.gov
Website - dc.lbl.gov

